SK12V314PH PEAK DISCHARGE CURRENT TEST

1. BMS Discharge Protection Settings

• ≥260A: Protection triggered, delay time: 1 minute

• ≥500A: Protection triggered, delay time: 15 seconds

• ≥800A: Protection triggered, delay time: 10 seconds

Recommended maximum continuous discharge current: 200A




2. Testing Process

We set different discharge current values to test whether they meet the expected requirements.

• Step 1: Discharge current 257A (below the protection threshold of 260A),


Setting Time: 2 minutes.

Result: Protection not triggered.



• Step 2: Discharge current 265A (above the protection threshold of 260A). Result: Protection triggered after 1 minute.






• Step 3: Discharge current 495A. (Close to but not above 500A)

Result: Protection triggered after 1 minute. (Execute based on the protection time exceeding 260A)






• Step 4: Discharge current 515A.

Result: Protection triggered after 15 seconds, meeting expectations.




515A Discharge



• Step 5: Discharge current 700A.


Result: Protection triggered after 15 seconds, meeting expectations.





• Step 6: Discharge current 800A.

Result: Protection triggered after 10 seconds, meeting expectations.





3. Short-Circuit Testing

With a high continuous current, are you concerned whether the short-circuit protection works effectively? Let us verify the short-circuit protection.

Battery internal resistance to be $1.65m\Omega$ External wiring resistance to be $2.16m\Omega$. Then start short-circuiting testing







Result: The data captured by the oscilloscope shows a short-circuit current of 2kA and a short-circuit duration of 2.76ms.