

Type Examination Certification



Certificate Number : C11341101

Company Name and Location : Enphase Energy
1420 North McDowell Blvd.
Petaluma, CA 9495

Product : EnvoyS (Board: 800-00550-0204)

Product Serial Nos. : Refer to UL Test Report, R11341101 (APPENDIX A)

Date of Report : August 26, 2016

Testing Location : 12 Laboratory Drive, RTP, NC 27709

Test Specifications : Enphase Test Plan
Reference Standards: ANSI C12.20-2010, ANSI C12.1-2008

Test Results : The above product was found to be compliant to ANSI C12.20-2010, Class 0.5

It is the responsibility of the company shown above that the products it produces are in compliance with the applicable requirements and identical to the sample(s) actually tested. Complete test results of the testing can be found in the report referenced above.

The name of UL LLC, any abbreviation thereof, or any symbol shall not be used on or in connection with the product unless and until specifically authorized by UL LLC.

Staff Engineer:

Date: 2016-08-26

Program Manager:

Date: 2016-08-26

